N.C. Department of Environmental, Health, and Natural Resources
Division of Laboratory Services
State Laborabory of Public Health
P.O.Box 28047 - 4312 District Drive
Raleigh, NC 27611-8047

DO NOT WRITE IN THIS SPACE

## **BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM**

Laboratory ID #:	<u>37501</u>	County:	Robeson
Water System ID #:	03-78-015	_	
Name of System:	Red Springs		
Sample Type:	5 (1 = Routine	; 2 = Repeat; 3 =	Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE	<u>10/16/13</u>	TIME:10:	:46 AM_
Location where collected	d: Kitchen sink @	128 Providenc	ce Place
Location Type:	(1 = Entry Ta	ap; 2 = General T	Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code:		Collected B	By: Keith Puckett
FOR REPEAT SAMPLE	:		FOR REPLACEMENT SAMPLE:
Previous Positive	Location Code:		Original Sample Type:
Positive Collection	n Date:		(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
	Time:		Original Collection Date:
Proximity:			Time:
(1 = Same; 2 = Ups	tream; 3 = Downstream)		
Mail Results To:			Type of Supply:
FAYETTEVILLE	REGIONAL OFFICE	E PWSS	X Community NTNC
225 GREEN ST	REET		Non-Community Private
FAYETTEVILLE			Type of Treatment: Chlorinated
			Non-Chlorinated
Telephone No.	9104861191		Free Chlorine Residual: 0.7 mg/
EIN #: 5620331 <sup>2</sup>	16M COU	RIER #: 14-56	6-48 Total Chlorine Residual: 1.0 mg/
	RESULTS		INVALID CODES
	PRESENT P223B	ABSENT  X  /ml	INVALID  1) Confluent Growth/No Coliform Found 2) TNTC/No Coliform Found 3) Turbid Culture/No Coliform Found 4) Over 30 Hours Old 5) Improper Sample or Analysis
Repeat Samples Rec	(numbe quired	Replacement Samples Required	
Date Analysis Begun:	10/17/13		Time Analysis Begun: 08:55 AM
Date Analysis Completed: 10/18/13			Time Analysis Completed: 09:25 AM
Laboratory Log #:			Certified By: Susan Beasley
COMMENTS: Spe	ecial / Non-compliance	, Fe 0.3 ppm, 8.	3.0 units pH, Gerald Kerns Susakasley
res	idence		