



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:
**HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
HENDERSONVILLE, NC 28792
EIN:566000307EH**

Name of System:
**J STARLING
3195 N CLEAR CREEK RD**

COURIER #: 06-92-01

StarLiMS Sample ID: **ES101916-0109001**

Collected: 10/18/2016 08:50
Received: 10/19/2016 08:28 **Jeffery Stepp
Angela Heybroek**

ES Microbiology ID:
GPS Number:

Sample Source: **New Well**
Sampling Point: **Well tap** Well Permit Number:
16100105101

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Date
Total Coliform, Colilert	Absent	10/20/2016
<i>E. coli</i> , Colilert	Absent	10/20/2016

Report Date: 10/20/2016

Reported By: Cindy Price

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.