North Carolina State Laboratory Public Health

Environmental Sciences

Microbiology

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
http://slph.state.nc.us
Phone: 919-733-7834
Fax: 919-733-8695

Certificate of Analysis

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - SUITE 100
HENDERSONVILLE, NC 28792

Name of System:

Southern Showcase
49 Deer Pointe Dr.
HENDERSONVILLE, NC 28792

StarLiMS Sample ID: **ES102209-0054001**

Collected: 10/21/2009 08:33 **Curt Cline**
Received: 10/22/2009 09:54 **Angela Heybroek**

ES Microbiology ID: **10474**
GPS Number:

Sample Source: **New Well**
Sampling Point: **Well Tap**

Well Permit Number: **09100107969**

Sample Description:
Comment:

Environmental Microbiology - Colilert Profile **Method:** SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Joy Hayes	10/23/2009
E. coli, Colilert	Absent	Joy Hayes	10/23/2009

Report Date: 10/26/2009 **Reported By:** *Susan Beasley*