

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: **37501** County: **Randolph**
Water System ID #: **30-76-014**
Name of System: **Haldoh Baptist Church**
Sample Type: **5** (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: **10/24/11** TIME: **10:10 AM**
Location where collected: **Outside tap old**
Location Type: ☐ (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: _____ Collected By: **Blair Murray**

FOR REPEAT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: ☐
(1 = Same; 2 = Upstream; 3 = Downstream)

FOR REPLACEMENT SAMPLE:

Original Sample Type: ☐
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To:

WINSTON SALEM REGIONAL OFFICE PWSS

WINSTON SALEM, NC 27107-2241

Telephone No. 336-771-5000

EIN #: 56 6000372 XX COURIER #: 13-15-01

Type of Supply:

☐ Community ☐ NTNC
☐ Non-Community ☐ Private

Type of Treatment:

☐ Chlorinated
☐ Non-Chlorinated
Free Chlorine Residual: _____
Total Chlorine Residual: _____

RESULTS

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	9223B	☐	☒	☐
Fecal/E. Coli	_____	☐	☐	☐
Heterotrophic P.C.	_____	_____/ml (number)		

☐ Repeat Samples Required

Date Analysis Begun: **10/25/11**
Date Analysis Completed: **10/26/11**
Laboratory Log #: **31440**

COMMENTS: **Special/Non-compliance, System Type: TNC, Water Source: GW**

INVALID CODES

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

☐ Replacement Samples Required

Time Analysis Begun: **09:10 AM**
Time Analysis Completed: **09:15 AM**
Certified By: **Susan Beasley**

