



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - SUITE 1

HENDERSONVILLE, NC 28792
EIN:566000307EH

COURIER #: 06-92-01

Name of System:
ALBERT F. FINN JR.

408 SHADOW MTN. LANE
HENDERSONVILLE, NC 28792

StarLiMS Sample ID:	ES103012-0096001	Collected:	10/29/2012	09:00	Krissie Red
		Received:	10/30/2012	08:39	Angela Heybroek
ES Microbiology ID:	40870	Sample Source:	New Well		Well Permit Number:
GPS Number:		Sampling Point:	Well		12100110654

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Darneice Lyons	10/31/2012
<i>E. coli</i> , Colilert	Absent	Darneice Lyons	10/31/2012

Report Date: 11/05/2012

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.