

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: 37501 County: STOKES
Water System ID #: 02-85-521
Name of System: SMITHS GROCERY & GRILL
Sample Type: 5 (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: 11/14/16 TIME: 08:30 AM
Location where collected: KITCHEN WASH SINK
Location Type: (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: E01 Collected By: Blair Murray

FOR REPEAT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity:
(1 = Same; 2 = Upstream; 3 = Downstream)

FOR REPLACEMENT SAMPLE:

Original Sample Type:
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To:
WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
WINSTON SALEM, NC 27105
Telephone No. 3367769800
EIN #: 566000372X

Type of Supply:
 Community NTNC
 Non-Community Private
Type of Treatment: Chlorinated
 Non-Chlorinated
Free Chlorine Residual: _____
Total Chlorine Residual: _____

RESULTS

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	<u>9223B</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fecal/E. Coli	_____	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heterotrophic P.C.	_____	_____/ml		
		(number)		

INVALID CODES

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

Repeat Samples Required

Replacement Samples Required

Date Analysis Begun: 11/15/16
Date Analysis Completed: 11/16/16
Laboratory Log #: _____

Time Analysis Begun: 09:30 AM
Time Analysis Completed: 09:50 AM
Certified By: Susan Beasley

COMMENTS: Special / Non-compliance (SP), System Type: TNC, Water Source: GW

