

BACTERIOLOGICAL ANALYSIS - PUBLIC WATER SYSTEM

Laboratory ID #: **37501** County: **Alamance**
Water System ID #: **02-01-569**
Name of System: **Burlington Moose Lodge**
Sample Type: **5** (1 = Routine; 2 = Repeat; 3 = Replacement; 4 = Plan Approval; 5 = Other)
Collected on: DATE: **11/28/11** TIME: **09:15 AM**
Location where collected: **Well head**
Location Type: **4** (1 = Entry Tap; 2 = General Tap; 3 = End Tap; 4 = Source/Intakes; 5 = Other)
Location Code: **007** Collected By: **Blair Murray**

FOR REPEAT SAMPLE:

Previous Positive Location Code: _____
Positive Collection Date: _____
Time: _____
Proximity: ☐ (1 = Same; 2 = Upstream; 3 = Downstream)

FOR REPLACEMENT SAMPLE:

Original Sample Type: ☐
(1=Routine; 2=Repeat; 3=Plan Approval; 4=Other)
Original Collection Date: _____
Time: _____

Mail Results To:

WINSTON SALEM REGIONAL OFFICE PWSS

WINSTON SALEM, NC 27107-2241

Telephone No. 336-771-5000

EIN #: 56 6000372 XX COURIER #: 13-15-01

Type of Supply:

☐ Community ☐ NTNC
☒ Non-Community ☐ Private

Type of Treatment:

☐ Chlorinated
☒ Non-Chlorinated

Free Chlorine Residual: _____

Total Chlorine Residual: _____

RESULTS

CONTAMINANT	METHOD	PRESENT	ABSENT	INVALID
Total Coliform	9223B	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fecal/E. Coli	_____	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Heterotrophic P.C.	_____	_____/ml		
(number)				

☐ Repeat Samples Required

Date Analysis Begun: **11/29/11**

Date Analysis Completed: **11/30/11**

Laboratory Log #: **32224**

COMMENTS: _____

INVALID CODES

- 1) Confluent Growth/No Coliform Found
- 2) TNTC/No Coliform Found
- 3) Turbid Culture/No Coliform Found
- 4) Over 30 Hours Old
- 5) Improper Sample or Analysis

☐ Replacement Samples Required

Time Analysis Begun: **08:40 AM**

Time Analysis Completed: **09:35 AM**

Certified By: **Susan Beasley**

