



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
306 N. Wilmington St.
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7834
Fax: 919-733-8695

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH

1200 SPARTANBURG HWY - SUITE 100
HENDERSONVILLE, NC 28792

EIN:566000307EH

Name of System:

KATHY THOMPSON (DAYCARE)
151 BIG WILLOW RD
HENDERSONVILLE, NC 28739

COURIER #: 06-92-01

StarLiMS Sample ID: **ES120111-0061001**



Collected: 11/30/2011 08:39

Received: 12/01/2011 08:30

Curt Cline

Joy Hayes

ES Microbiology ID: **32335**

GPS Number:

Sample Source: **Well**

Sampling Point: **2 comp sink**

Well Permit Number:

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Present	Joy Hayes	12/02/2011
<i>E. coli</i> , Colilert	Present	Joy Hayes	12/02/2011

Report Date: 12/05/2011

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.