



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:
HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - SUITE 1

HENDERSONVILLE, NC 28792
EIN:566000307EH **COURIER #: 06-92-01**

DAVID GOLDSTEIN

StarLiMS Sample ID: **ES120413-0056001** Collected: 12/03/2013 08:56 **Curt Cline**
 Received: 12/04/2013 09:10 **Angela Heybroek**

ES Microbiology ID: Sample Source: **New Well** Well Permit Number:
GPS Number: Sampling Point: **Well** **12120114218**

Sample Description:
Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	HLBRASWELL	12/05/2013
<i>E. coli</i> , Colilert	Absent	HLBRASWELL	12/05/2013

Report Date: 12/16/2013

Reported By: Susan Beasley

Susan Bradley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.