



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100

HENDERSONVILLE, NC 28792

EIN:566000307EH

COURIER #: 06-92-01

Name of System:

THE BROADWAY GROUP
651 BROOKSIDE CAMP RD.

StarLIMS Sample ID: ES120717-0082001



Collected: 12/06/2017 09:00

Received: 12/07/2017 08:19

Cody Robertson

Angela Heybroek

ES Microbiology ID:

Sample Source: New Well

Well Permit Number:

GPS Number:

Sampling Point: well tap

17010100050

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Date
Total Coliform, Colilert	Present	12/08/2017
<i>E. coli</i> , Colilert	Absent	12/08/2017

Report Date: 12/11/2017

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.