



North Carolina State Laboratory Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

P.O. Box 28047
4312 District Drive
Raleigh, NC 27611-8047
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

Report To:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100

Name of System:

KERNAN FENDER

4571 SUGARLOAF RD.

HENDERSONVILLE, NC 28792

EIN:566000307EH

COURIER #: 06-92-01

StarLiMS Sample ID: ES121316-0114001



Collected: 12/12/2016 09:00

Received: 12/13/2016 08:51

Cody Robertson

Angela Heybroek

ES Microbiology ID:

Sample Source: New Well

Well Permit Number:

GPS Number:

Sampling Point: well tap

16100106433

Sample Description:

Comment:

Environmental Microbiology - Colilert Profile

Method: SM 9223B

Test Name: Colilert

Analyte	Test Result	Date
Total Coliform, Colilert	Absent	12/14/2016
<i>E. coli</i> , Colilert	Absent	12/14/2016

Report Date: 12/16/2016

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.