



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: ERIC HUDSON

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
WINSTON SALEM, NC 27105

Bible Wesleyan Ch & Christian Sch
System Type: NTNC, Location: 001
Boys RR-School, Water Source: GW

EIN: 566000372X

Delivery: NC Courier

StarLiMS ID: **ES180703-0013**

Date Collected: 07/02/2018

Time Collected: 13:27

Date Received: 07/03/2018

Time Received: 08:16

Denise Richardson

Sample Source:

Sampling Point:

Sample Type:

GPS No.

Treatment:

Well Permit No.

Comment:

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/05/2018
E. coli	Absent			07/05/2018

Report Date: 07/06/2018

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.