



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: CODY ROBERTSON

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
HENDERSONVILLE, NC 28792

William Laughter
111 Tullahoma Farms Ln
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

HENDERSON County

StarLiMS ID: **ES180724-0070**

Date Collected: 07/23/2018

Time Collected: 09:00

By: Sasha Bowery

Date Received: 07/24/2018

Time Received: 08:17

By: Susan Beasley

Sample Source: Well water

Sampling Point: Kitchen sink

Sample Type:

GPS No.

Treatment:

Well Permit No. 18090114165

Comment:

Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/24/2018
E. coli	Absent			07/24/2018

Report Date: 07/25/2018

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.