



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: **CODY ROBERTSON**

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
HENDERSONVILLE, NC 28792

Mary Goodwin
1916 S Lake Summit Rd
Saluda, NC 28773

EIN: 566000307EH

Delivery: NC Courier

HENDERSON County

StarLiMS ID: ES180726-0004	Date Collected: 07/25/2018	Time Collected: 08:45	By: Sasha Bowery
	Date Received: 07/26/2018	Time Received: 07:44	By: Denise Richardson
Sample Source: Well water	Sampling Point: Outside tap		
Sample Type:	GPS No.		
Treatment:	Well Permit No. 04090173550		

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			07/26/2018
E. coli	Absent			07/26/2018

Report Date: 07/30/2018

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.