



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Doug Whitmire

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 WINSTON SALEM, NC 27105

**Lawsonville Road Baptist Church**

**EIN:** 566000372X

**Delivery:** NC Courier

**ROCKINGHAM County**

StarLiMS ID: **ES180802-0008**

Date Collected: 08/01/2018

Time Collected: 12:52 By: Doug Whitmire

Date Received: 08/02/2018

Time Received: 07:48 By: Darneice Owens

Water System ID: 02-79-476

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Wellhead

Location Type:

Location Code: W01

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

| Analyte        | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Present     |      |            | 08/02/2018  |
| E. coli        | Absent      |      |            | 08/02/2018  |

**Report Date:** 08/03/2018

**Reported By:** Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.