



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
http://slph.ncpublichealth.com  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: Blair Murray

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS  
450 WEST HANES MILL RD STE 300  
WINSTON SALEM, NC 27105

Holly Ridge G C

EIN: 566000372X

Delivery: NC Courier

RANDOLPH County

StarLiMS ID: **ES180807-0065**

Date Collected: 08/06/2018

Time Collected: 14:00 By: Blair Murray

Date Received: 08/07/2018

Time Received: 08:21 By: Susan Beasley

Water System ID: 00-00-000

System Type: NTNC

Water Source: Ground Water

Facility ID: D01

Sample Type: Special/Non-Compliance

Sample Location: Kitchen sink

Location Type:

Location Code: KS1

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			08/08/2018
E. coli	Absent			08/08/2018

Report Date: 08/08/2018

Reported By: Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.