



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: MIKE LEWIS

Name of System:

FAYETTEVILLE REGIONAL OFFICE PWSS
 225 GREEN ST STE 714
 Fayetteville, NC 28301

Heritage Bible Fellowship

EIN: 562033116M

Delivery: NC Courier

Cumberland County

| | | | |
|-----------------------------------|----------------------------|-------------------------------------|---------------------|
| StarLiMS ID: ES180906-0064 | Date Collected: 09/05/2018 | Time Collected: 10:15 | By: Mike Lewis |
| | Date Received: 09/06/2018 | Time Received: 09:01 | By: Angela Heybroek |
| Water System ID: 53-26-406 | System Type: NC | Water Source: Ground Water | |
| Facility ID: | | Sample Type: Special/Non-Compliance | |
| Sample Location: Kitchen faucet | Location Type: | Location Code: K01 | |
| Disinfectant Used: | Free Chlorine: 0.00 mg/L | Total Chlorine: 0.00 mg/L | |

Comments:

PWS - Colilert Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 09/06/2018 |
| E. coli | Absent | | | 09/06/2018 |

Report Date: 09/07/2018

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.