



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Shawn Fox

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 Winston Salem, NC 27105

**Kirby's MHP**

**EIN:** 566000372X

**Delivery:** Hand Delivered

**Alamance County**

StarLIMS ID: **ES180925-0126**

Date Collected: 09/25/2018

Time Collected: 08:09 By: Shawn Fox

Date Received: 09/25/2018

Time Received: 09:54 By: Angela Heybroek

Water System ID: 02-01-118

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: O/S spigot -Lot #27

Location Type:

Location Code: 005

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments: Outside spigot - Lot #27 - Resample #2

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			09/25/2018
E. coli	Absent			09/25/2018

**Report Date:** 09/26/2018

**Reported By:** Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.