



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Jeff Bryan

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 Winston Salem, NC 27105

**Davidson Water Inc**  
 4596 Glenview Dr

**EIN:** 566000372X

**Delivery:** NC Courier

**Davidson County**

StarLiMS ID: <b>ES180927-0054</b>	Date Collected: 09/26/2018	Time Collected: 09:52	By: J Bryan
	Date Received: 09/27/2018	Time Received: 08:29	By: Denise Richardson
Water System ID: 02-29-025	System Type: C	Water Source: Surface Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location:	Location Type:	Location Code:	
Disinfectant Used:	Free Chlorine: 1.07 mg/L	Total Chlorine:	

Comments: Disinfectant Used: Chlorine

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			09/27/2018
E. coli	Absent			09/27/2018

**Report Date:** 09/28/2018

**Reported By:** Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.