



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: **TRENTON HILL**

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Jonathan Jackson
1001 N. Prestonwood Dr.

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES181002-0123** Date Collected: 10/01/2018 Time Collected: 09:10 By: Trenton Hill
Date Received: 10/02/2018 Time Received: 09:10 By: Susan Beasley

Sample Source: New Well Sampling Point: Well head
Sample Type: Raw GPS No.
Treatment: Well Permit No. 15100109965

Comment:

Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/02/2018
E. coli	Absent			10/02/2018

Report Date: 10/03/2018

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.