



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Tammy Taylor

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Forbush High School

EIN: 566000372X

Delivery: NC Courier

Yadkin County

StarLiMS ID: ES181009-0102	Date Collected: 10/08/2018	Time Collected: 10:40	By: Tammy Taylor
	Date Received: 10/09/2018	Time Received: 09:05	By: Susan Beasley
Water System ID: 02-99-412	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Kitchen tap	Location Type:	Location Code: M01	
Disinfectant Used:	Free Chlorine: 0.50 mg/L	Total Chlorine:	

Comments: Disinfectant Used: Chlorine

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/09/2018
E. coli	Absent			10/09/2018

Report Date: 10/15/2018

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.