



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: Blair Murray

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS  
450 WEST HANES MILL RD STE 300  
Winston Salem, NC 27105

Bethel Baptist Church

EIN: 566000372X

Delivery: NC Courier

Stokes County

StarLiMS ID: **ES181017-0053**

Date Collected: 10/16/2018

Time Collected: 08:55 By: Blair Murray

Date Received: 10/17/2018

Time Received: 08:21 By: Denise Richardson

Water System ID: 02-85-403

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Well head

Location Type:

Location Code: W01

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/17/2018
E. coli	Absent			10/17/2018

Report Date: 10/19/2018

Reported By: Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.