



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: ALLEN BAKER**

**Name of System:**

**WILMINGTON REGIONAL OFFICE PWSS**  
**127 CARDINAL DRIVE EXTENSION**  
**Wilmington, NC 28405**

**Eastern Park**

**EIN: 566000372Q**

**Delivery: NC Courier**

**Carteret County**

StarLiMS ID: <b>ES181024-0060</b>	Date Collected: 10/23/2018	Time Collected: 10:26	By: Allen Baker
	Date Received: 10/24/2018	Time Received: 08:42	By: Angela Heybroek
Water System ID: 04-16-502	System Type: NTNC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Concess. stand sink	Location Type:	Location Code:	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments:

**PWS - Colisure Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/24/2018
E. coli	Absent			10/24/2018

**Report Date:** 10/26/2018

**Reported By:** **Susan Beasley**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.