



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: JONATHAN STEPP

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Sandra Rainey
67 Songbird Ct
Gerton, NC 28735

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES181219-0094** Date Collected: 12/18/2018 Time Collected: 08:45 By: Jonathan Stepp
Date Received: 12/19/2018 Time Received: 08:48 By: Susan Beasley

Sample Source: New Well Sampling Point: Well head
Sample Type: Raw GPS No.
Treatment: Well Permit No. 17120103587

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			12/19/2018
E. coli	Absent			12/19/2018

Report Date: 12/27/2018

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.