



# North Carolina State Laboratory of Public Health

*Environmental Sciences*

**Microbiology**

**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: CURT CLINE

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

**Norm Erhike**  
930 Big Raven Ln  
Saluda, NC 28773

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES190109-0129** Date Collected: 01/08/2019 Time Collected: 08:13 By: Curt Cline  
Date Received: 01/09/2019 Time Received: 09:23 By: Angela Heybroek

Sample Source: New Well Sampling Point: Front tap  
Sample Type: Raw GPS No.  
Treatment: Well Permit No. 18100105280

Comment:

## Colilert Profile

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			01/09/2019
E. coli	Absent			01/09/2019

Report Date: 01/11/2019

Reported By: **Susan Beasley**

## Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.