



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Walker Keel

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
450 WEST HANES MILL RD STE 300
Winston Salem, NC 27105

Country Living Apts
1100 Advent Dr
Germanton, NC 27019

EIN: 566000372X

Delivery: NC Courier

Stokes County

StarLiMS ID: ES190117-0051	Date Collected: 01/16/2019	Time Collected: 16:30	By: Walker Keel
	Date Received: 01/17/2019	Time Received: 08:16	By: Angela Heybroek
Water System ID: 02-85-130	System Type: C	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Kitchen	Location Type:	Location Code:	
Disinfectant Used:	Free Chlorine:	Total Chlorine:	

Comments: Disinfectant Used: Chlorine, Sample date/time of collection given by phone per W. Keel.

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			01/17/2019
E. coli	Absent			01/17/2019

Report Date: 01/18/2019

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.