



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: **Sasha Bowery**

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Kelly Horan
7 Conger Dr
Hendersonville, NC 28739

EIN: **566000307EH**

Delivery: **NC Courier**

Henderson County

StarLiMS ID: **ES190313-0102** Date Collected: 03/12/2019 Time Collected: 08:45 By: **Sasha Bowery**
Date Received: 03/13/2019 Time Received: 08:31 By: **Susan Beasley**

Sample Source: New Well Sampling Point: Well head
Sample Type: Raw GPS No.
Treatment: Well Permit No. 18120105292

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			03/13/2019
E. coli	Absent			03/13/2019

Report Date: 03/15/2019

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.