



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: MIKE LEWIS**

**Name of System:**

**FAYETTEVILLE REGIONAL OFFICE PWSS**  
**225 GREEN ST STE 714**  
**Fayetteville, NC 28301**

**Red Branch Baptist Church**

**EIN: 562033116M**

**Delivery: NC Courier**

**Moore County**

StarLiMS ID: **ES190409-0043**

Date Collected: 04/08/2019

Time Collected: 11:00 By: Mike Lewis

Date Received: 04/09/2019

Time Received: 08:55 By: Angela Heybroek

Water System ID: 03-63-527

System Type: NC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Kitchen sink

Location Type:

Location Code: K01

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			04/09/2019
E. coli	Absent			04/09/2019

**Report Date:** 04/12/2019

**Reported By:** **Susan Beasley**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.