



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: ALLEN BAKER

Name of System:

WILMINGTON REGIONAL OFFICE PWSS  
127 CARDINAL DRIVE EXTENSION  
Wilmington, NC 28405

Outer Island General Store

EIN: 566000372Q

Delivery: NC Courier

Carteret County

StarLiMS ID: **ES190522-0056**      Date Collected: 05/21/2019      Time Collected: 10:27      By: Allen Baker  
Date Received: 05/22/2019      Time Received: 08:11      By: Tyler Best  
Water System ID: 04-16-529      System Type: NTNC      Water Source: Ground Water  
Facility ID:      Sample Type: Special/Non-Compliance  
Sample Location: 3-compartment sink      Location Type:      Location Code:  
Disinfectant Used:      Free Chlorine:      Total Chlorine:

Comments:

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			05/22/2019
E. coli	Absent			05/22/2019

Report Date: 05/23/2019

Reported By: Susan Beasley

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.