



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: **Sasha Bowery**

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Ronald Delbuono
4326 Chimney Rock Rd

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES190523-0078	Date Collected: 05/22/2019	Time Collected: 08:45	By: Sasha Bowery
	Date Received: 05/23/2019	Time Received: 08:32	By: Angela Heybroek
Sample Source: New Well	Sampling Point: Well head		
Sample Type: Raw	GPS No.		
Treatment:	Well Permit No. 18100114538		

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			05/23/2019
E. coli	Absent			05/23/2019

Report Date: 05/29/2019

Reported By: **Susan Beasley**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.