



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: JOEY WHITE**

**Name of System:**

**WASHINGTON REGIONAL OFFICE PWSS**  
**943 WASHINGTON SQUARE MALL**  
**Washington, NC 27889**

**Sandy Point Resort**  
**111 Spoonbill Dr**

**EIN: 562033116F**

**Delivery: NC Courier**

**Currituck County**

StarLiMS ID: **ES190604-0049**

Date Collected: 06/03/2019

Time Collected: 11:30 By: Joey White

Date Received: 06/04/2019

Time Received: 08:06 By: Tyler Best

Water System ID: 04-27-101

System Type: C

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location:

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine: 0.25 mg/L

Total Chlorine:

Comments: Disinfectant Used: Chlorine.

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/04/2019
E. coli	Absent			06/04/2019

**Report Date:** 06/05/2019

**Reported By:** **Susan Beasley**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.