



# North Carolina State Laboratory of Public Health

## Environmental Sciences

### Microbiology

### Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

#### FINAL REPORT

Report to: CURT CLINE

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

D & M Orchards Migrant Camp  
Behind #30 Ottanola Rd  
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES190606-0023** Date Collected: 06/05/2019 Time Collected: 08:11 By: Curt Cline  
Date Received: 06/06/2019 Time Received: 07:38 By: Angela Heybroek

Sample Source: Spring Sampling Point: Kitchen  
Sample Type: GPS No.  
Treatment: Well Permit No.

Comment: Spring with UV light treatment

#### Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/06/2019
E. coli	Absent			06/06/2019

Report Date: 06/10/2019

Reported By: **Susan Beasley**

#### Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.