



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: Mike Painter

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS  
450 WEST HANES MILL RD STE 300  
Winston Salem, NC 27105

Town of Jamestown  
301 E Main St  
Jamestown, NC 27282

EIN: 566000372X

Delivery: NC Courier

Guilford County

StarLiMS ID: **ES190606-0066**      Date Collected: 06/05/2019      Time Collected: 09:10      By: Mike Painter  
Date Received: 06/06/2019      Time Received: 08:48      By: Tyler Best  
Water System ID: 02-41-030      System Type: C      Water Source: Surface Water  
Facility ID:      Sample Type: Special/Non-Compliance  
Sample Location: Kitchenette sink      Location Type:      Location Code: 001  
Disinfectant Used:      Free Chlorine:      Total Chlorine: 2.3 mg/L

Comments: Disinfectant Used: Chloramines.

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			06/06/2019
E. coli	Absent			06/06/2019

Report Date: 06/10/2019

Reported By: Susan Beasley

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.