



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Shawn Fox

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Town of Green Level
 2510 Green Level Church Rd
 Green Level, NC

EIN: 566000372X

Delivery: NC Courier

Alamance County

StarLiMS ID: ES190716-0058	Date Collected: 07/15/2019	Time Collected: 13:58	By: Shawn Fox
	Date Received: 07/16/2019	Time Received: 08:40	By: Tyler Best
Water System ID: 02-01-030	System Type: C	Water Source: Surface Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Hand sink - shop	Location Type:	Location Code: 001	
Disinfectant Used:	Free Chlorine:	Total Chlorine: 3.2 mg/L	
Comments: Disinfectant Used: Chlorine/Ammonia (chloramines)			

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/16/2019
E. coli	Absent			07/16/2019

Report Date: 07/17/2019

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.