



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Shawn Fox

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 Winston Salem, NC 27105

**Town of Haw River**  
 114 S State Street  
 Haw River, NC 27258

**EIN:** 566000372X

**Delivery:** NC Courier

**Alamance County**

StarLiMS ID: <b>ES190717-0058</b>	Date Collected: 07/16/2019	Time Collected: 09:43	By: Shawn Fox
	Date Received: 07/17/2019	Time Received: 08:13	By: Tyler Best
Water System ID: 02-01-020	System Type: C	Water Source: Surface Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: OS tap-rt side of bldg	Location Type:	Location Code: 552	
Disinfectant Used:	Free Chlorine:	Total Chlorine: 3.0 mg/L	
Comments: Disinfectant Used: Chlorine/Ammonia (Chloramines)			

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/17/2019
E. coli	Absent			07/17/2019

**Report Date:** 07/18/2019

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.