



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to:** Shawn Fox

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
 450 WEST HANES MILL RD STE 300  
 Winston Salem, NC 27105

**New South Inc - Pond Well**  
 4408 Mt Hermon - Rock Creek Rd  
 Graham, NC 27253

**EIN:** 566000372X

**Delivery:** Hand Delivered

**Alamance County**

StarLiMS ID: **ES190730-0087**

Date Collected: 07/29/2019

Time Collected: 13:38 By: Shawn Fox

Date Received: 07/30/2019

Time Received: 10:22 By: Angela Heybroek

Water System ID: 02-01-625

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Well # 1

Location Type:

Location Code: W01

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			07/30/2019
E. coli	Absent			07/30/2019

**Report Date:** 07/31/2019

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.