



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Sasha Bowery

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Irina David
167 Shiloh Dr

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES190821-0095**

Date Collected: 08/20/2019

Time Collected: 09:00

By: Sasha Bowery

Date Received: 08/21/2019

Time Received: 08:29

By: Angela Heybroek

Sample Source: Well water

Sampling Point: Faucet at well house

Sample Type: Raw

GPS No.

Treatment:

Well Permit No.

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/21/2019
E. coli	Absent			08/21/2019

Report Date: 08/22/2019

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.