



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Tim Appelboom

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Newsome MHP & Campground
 211 HB Newsom PI
 Denton, NC 27239

EIN: 566000372X

Delivery: NC Courier

Davidson County

StarLiMS ID: ES190829-0049	Date Collected: 08/28/2019	Time Collected: 10:30	By: Tim Appelboom
	Date Received: 08/29/2019	Time Received: 08:09	By: Angela Heybroek
Water System ID: 30-29-002	System Type: NC	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Bathroom tap	Location Type:	Location Code: EOS	
Disinfectant Used:	Free Chlorine: 0.39 mg/L	Total Chlorine:	

Comments: Disinfectant Used: Sodium Hypochlorite.

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/29/2019
E. coli	Absent			08/29/2019

Report Date: 08/30/2019

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.