



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Ronda Dufour

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Tim Phillips
24 Hunters View Dr
Hendersonville, NC 28792

EIN: 566000307EH

Delivery: NC Courier

Henderson County

| | | | |
|-----------------------------------|-----------------------------|-----------------------|---------------------|
| StarLiMS ID: ES190911-0096 | Date Collected: 09/10/2019 | Time Collected: 09:00 | By: Ronda Dufour |
| | Date Received: 09/11/2019 | Time Received: 08:35 | By: Angela Heybroek |
| Sample Source: New Well | Sampling Point: Well head | | |
| Sample Type: Raw | GPS No. | | |
| Treatment: | Well Permit No. 17120114674 | | |

Comment:

Colilert Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent | | | 09/11/2019 |
| E. coli | Absent | | | 09/11/2019 |

Report Date: 09/12/2019

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.