



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
 http://slph.ncpublichealth.com
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: Tim Appelboom

Name of System:

WINSTON SALEM REGIONAL OFFICE PWSS
 450 WEST HANES MILL RD STE 300
 Winston Salem, NC 27105

Quail Acres MHP
 135 Quail Acres Dr
 Stokesdale, NC 27357

EIN: 566000372X

Delivery: NC Courier

Rockingham County

StarLiMS ID: ES190919-0055	Date Collected: 09/18/2019	Time Collected: 10:05	By: Tim Appelboom
	Date Received: 09/19/2019	Time Received: 08:20	By: Angela Heybroek
Water System ID: 02-79-157	System Type: C	Water Source: Ground Water	
Facility ID:		Sample Type: Special/Non-Compliance	
Sample Location: Bathroom sink	Location Type:	Location Code: 135	
Disinfectant Used:	Free Chlorine: 3.1 mg/L	Total Chlorine:	
Comments: Disinfectant Used: Sodium hypochlorite.			

PWS - Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			09/19/2019
E. coli	Absent			09/19/2019

Report Date: 09/20/2019

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.