



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: ALLEN BAKER**

**Name of System:**

**WILMINGTON REGIONAL OFFICE PWSS**  
**127 CARDINAL DRIVE EXTENSION**  
**Wilmington, NC 28405**

**Snows Cut Estuarine Access Park**

**EIN: 566000372Q**

**Delivery: NC Courier**

**New Hanover County**

StarLiMS ID: **ES190924-0050**

Date Collected: 09/23/2019

Time Collected: 10:44 By: Allen Baker

Date Received: 09/24/2019

Time Received: 08:21 By: Angela Heybroek

Water System ID: 04-65-560

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: Storage room faucet

Location Type:

Location Code:

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			09/24/2019
E. coli	Absent			09/24/2019

**Report Date:** 09/25/2019

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.