



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
 MSC 1918
 Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
 Phone: 919-733-7308
 Fax: 919-715-8611

FINAL REPORT

Report to: MIKE LEWIS

Name of System:

FAYETTEVILLE REGIONAL OFFICE PWSS
225 GREEN ST STE 714
Fayetteville, NC 28301

The Heritage Campground & Rec

EIN: 562033116M

Delivery: NC Courier

Moore County

StarLiMS ID: **ES191009-0041**

Date Collected: 10/08/2019

Time Collected: 11:20 By: Mike Lewis

Date Received: 10/09/2019

Time Received: 08:10 By: Angela Heybroek

Water System ID: 03-63-141

System Type: NC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location: At well

Location Type:

Location Code: RW1

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

PWS - Colisure Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			10/09/2019
E. coli	Absent			10/09/2019

Report Date: 10/10/2019

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.