



North Carolina State Laboratory of Public Health  
Environmental Sciences  
Microbiology  
Certificate of Analysis

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

FINAL REPORT

Report to: JONATHAN STEPP

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

Chad Slater  
485 Shiloh Dr  
Hendersonville, NC 28739

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES191106-0036

Date Collected: 11/05/2019

Time Collected: 08:05

By: JAS

Date Received: 11/06/2019

Time Received: 08:07

By: Angela Heybroek

Sample Source: Well water

Sampling Point: Well head

Sample Type: Raw

GPS No.

Treatment:

Well Permit No.

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Present			11/06/2019
E. coli	Absent			11/06/2019

Report Date: 11/07/2019

Reported By: KPLEMMONS

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.