



North Carolina State Laboratory of Public Health
Environmental Sciences
Microbiology
Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918
<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Nicole Bishop

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

M.C. Ventures Inc
37 Spring Woods Ln
Flat Rock, NC 28731

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES191106-0056

Date Collected: 11/05/2019

Time Collected: 08:45

By: John Mahan / Nicole

Date Received: 11/06/2019

Time Received: 08:08

By: Angela Heybroek

Sample Source: New Well

Sampling Point: Well head

Sample Type: Raw

GPS No.

Treatment:

Well Permit No. 19100100756

Comment:

Colilert Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Present | | | 11/06/2019 |
| E. coli | Absent | | | 11/06/2019 |

Report Date: 11/07/2019

Reported By: KPLEMMONS

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.