



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Nicole Bishop

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

M.C. Ventures Inc
37 Spring Woods Lane
Flat Rock, NC

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES191119-0092** Date Collected: 11/18/2019 Time Collected: 08:30 By: N. Bishop
Date Received: 11/19/2019 Time Received: 08:43 By: Tyler Best

Sample Source: New Well Sampling Point: well head tap
Sample Type: Raw GPS No.
Treatment: Well Permit No. 19100100756

Comment:

Colilert - Quanti-Tray2000 Profile

Method: SM 9223B

| Analyte | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|-----------|------------|-------------|
| Total Coliform | 1 | MPN/100mL | Present | 11/19/2019 |
| E. coli | <1 | MPN/100mL | Absent | 11/19/2019 |

Report Date: 11/20/2019

Reported By: **KPLEMMONS**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.