



# North Carolina State Laboratory of Public Health

*Environmental Sciences*

**Microbiology**

**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

Report to: John Mahan

**Name of System:**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
1200 SPARTANBURG HWY - STE 100  
Hendersonville, NC 28792

**Paul McCray**  
0 McCray Dr

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES200115-0100** Date Collected: 01/14/2020 Time Collected: 09:00 By:  
Date Received: 01/15/2020 Time Received: 08:21 By: Angela Heybroek

Sample Source: New Well Sampling Point:

Sample Type: Raw GPS No.

Treatment: Well Permit No. 19100109647

Comment:

## Colilert Profile

**Method: SM 9223B**

| Analyte        | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent      |      |            | 01/15/2020  |
| E. coli        | Absent      |      |            | 01/15/2020  |

Report Date: 01/16/2020

Reported By: **KPLEMMONS**

## Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.