



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Erik Weber

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Marshall Frank
2846 Bob's Creek Rd.
Zirconia, NC 28790

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: ES200416-0115	Date Collected: 04/15/2020	Time Collected: 08:40	By: Erik Weber
	Date Received: 04/16/2020	Time Received: 09:40	By: Denise Richardson
Sample Source: New Well	Sampling Point: Well head		
Sample Type: Raw	GPS No.		
Treatment:	Well Permit No. 18100121950		

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			04/16/2020
E. coli	Absent			04/16/2020

Report Date: 04/17/2020

Reported By: CGOFORTH

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.