



North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive
MSC 1918
Raleigh, NC 27699-1918

<http://slph.ncpublichealth.com>
Phone: 919-733-7308
Fax: 919-715-8611

FINAL REPORT

Report to: Ronda Dufour

Name of System:

HENDERSON CO ENVIRONMENTAL HEALTH
1200 SPARTANBURG HWY - STE 100
Hendersonville, NC 28792

Brent Nix
290 Orchard Valley Dr.
Flat Rock, NC 28731

EIN: 566000307EH

Delivery: NC Courier

Henderson County

StarLiMS ID: **ES200528-0068**

Date Collected: 05/27/2020 Time Collected: 08:30 By: Ronda Dufour
Date Received: 05/28/2020 Time Received: 07:59 By: Denise Richardson

Sample Source: Well water

Sampling Point: Hose Bibb @ well

Sample Type:

GPS No.

Treatment:

Well Permit No. 20090107433

Comment:

Colilert Profile

Method: SM 9223B

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			05/28/2020
E. coli	Absent			05/28/2020

Report Date: 05/29/2020

Reported By: **CGOFORTH**

Explanations of Coliform Analysis:

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.