



**North Carolina State Laboratory of Public Health**  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
 MSC 1918  
 Raleigh, NC 27699-1918  
 http://slph.ncpublichealth.com  
 Phone: 919-733-7308  
 Fax: 919-715-8611

**FINAL REPORT**

**Report to: Seth Titley**

**Name of System:**

**WINSTON SALEM REGIONAL OFFICE PWSS**  
**450 WEST HANES MILL RD STE 300**  
**Winston Salem, NC 27105**

**Liberty Wesleyan**

**EIN: 566000372X**

**Delivery: NC Courier**

**Rockingham County**

StarLiMS ID: **ES200819-0036**

Date Collected: 08/18/2020

Time Collected: 14:15 By: Seth Titley

Date Received: 08/19/2020

Time Received: 08:03 By: Angela Heybroek

Water System ID: 02-79-748

System Type: NTNC

Water Source: Ground Water

Facility ID:

Sample Type: Special/Non-Compliance

Sample Location:

Location Type:

Location Code: KS1

Disinfectant Used:

Free Chlorine:

Total Chlorine:

Comments:

**PWS - Colilert Profile**

**Method: SM 9223B**

Analyte	Test Result	Unit	Conclusion	Date Tested
Total Coliform	Absent			08/19/2020
E. coli	Absent			08/19/2020

**Report Date:** 08/20/2020

**Reported By:** **KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.