



North Carolina State Laboratory of Public Health  
*Environmental Sciences*  
**Microbiology**  
**Certificate of Analysis**

4312 District Drive  
MSC 1918  
Raleigh, NC 27699-1918  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7308  
Fax: 919-715-8611

**FINAL REPORT**

**Report to: JONATHAN STEPP**

**HENDERSON CO ENVIRONMENTAL HEALTH**  
**1200 SPARTANBURG HWY - STE 100**  
**Hendersonville, NC 28792**

**Name of System:**

**Kenneth Paswer**  
**655 Hoopers Creech Rd.**  
**Fletcher, NC 28732**

**EIN: 566000307EH**

**Delivery: NC Courier**

**Henderson County**

StarLiMS ID: **ES200917-0051**

Date Collected: 09/16/2020

Time Collected: 08:10

By: Johnathan Stepp

Date Received: 09/17/2020

Time Received: 07:46

By: Denise Richardson

Sample Source: Well water

Sampling Point: Well head

Sample Type:

GPS No.

Treatment:

Well Permit No. 17120118335

Comment:

**Colilert Profile**

**Method: SM 9223B**

| Analyte        | Test Result | Unit | Conclusion | Date Tested |
|----------------|-------------|------|------------|-------------|
| Total Coliform | Absent      |      |            | 09/17/2020  |
| E. coli        | Absent      |      |            | 09/17/2020  |

**Report Date: 09/18/2020**

**Reported By: KPLEMMONS**

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.